



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00437

OWNER'S NAME: HELGESON

DATE: 11/21/2014

TYPE: Rough-in plumbing

TIME STARTED: 9:33 AM

INSPECTOR: Amber Green

MAP NUMBER: 19-15-08050-0004

	1. DWV still at zero.
	2. H2O (80#/15min) - OK

INSTRUCTIONS: All systems must be on test for inspection. Re-Fee, Re-Call

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?

☐ NO

☒ YES

\$ 65.00

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506