INSPECTION REPORT

PERMIT NUMBER:

BP-14-00516

OWNER'S NAME:

BV RESORT HOMES

DATE:		10/30/2014	TYPE:	Floor framing
TIME STARTED:		2:35 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:		20-15-19051-0037		
1	1. floor framing ok			
2	2. retofit pads not pored			
INSTRUCTIONS: Do not pour. Dig out reto pads and have inspected before pouring. Send engineer letter addressing pad revision				
	100	or addressing pad revision		
NEXT INSPECTION: retro pads and rebar				
RE-INSPECTION FEE DUE? NO YES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
jessica.contratto @co.kittitas.wa.us				
 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 				