INSPECTION REPORT

PERMIT NUMBER:	BP-14-00516	OWNER'S NAME:	BV RESORT HOMES
DATE:	1/20/2015	TYPE:	Framing
TIME STARTED:	12:30 PM	INSPECTOR:	Lou Whitford
MAP NUMBER:	20-15-19051-0037		
1. Girder Truss not to plan. Submit revision.			
2. Retrofit pad rebar not per plan on footing 21.			
3. Mechanical exhaust fan over toilet required.			
INSTRUCTIONS: Complete corrections.			
NEXT INSPECTION: Reinspect			
RE-INSPECTION FEE	OUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
lou.whitford @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			