



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00537 OWNER'S NAME: PITTS
DATE: 2/18/2015 TYPE: Frame-Plumb-Mech
TIME STARTED: 12:08 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-15-29051-0092

	1. Gas Line at 13# Required to be 15#/15min.
	2. Heating/Exhaust Ducting OK.
	3. Top Plate Strap at Bedroom #2
	4. Top Plate Strap at Low Volt Closet
	5. Top Plate Strap in Bathroom Wall Across from Laundry.
	6. DWV Stack Test Leaking.
	7. Trusses OK.
	8. Fireplace Draft Stop Not Complete.
	9. Fireplace Manual Not Accesible.
	10. Great Room Ridge to Rafter Rafter to Ledger Detail Required.
	11. Covered Porch Rafter to PT GluLam Detail Required.
	12. Post to Concrete Column Connection Required. Remove OSB for Visual Inspection.
	13. 4 Ply Girder in Master Bath Closet Next to Aundry needs Addtl. Posting.

INSTRUCTIONS: Complete Corrections Above.

NEXT INSPECTION: ReInspect.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00537

OWNER'S NAME: PITTS

DATE: 2/18/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 12:08 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29051-0092

	Page 2

INSTRUCTIONS: Complete Corrections Above.

NEXT INSPECTION: ReInspect.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506