INSPECTION REPORT

TYPE:

INSPECTOR:

BP-14-00537

3/2/2015

10:56 AM

PERMIT NUMBER:

TIME STARTED:

DATE:

OWNER'S NAME:

PITTS

Insulation

Jeremy Haberman

MAP NUMBER:	20-15-29051-0092
1. Insula	ation OK.
2. Corre	ections OK.
3. Firep	lace Requires Accesible Gas Shutoff
INSTRUCTIONS: [Do Not Cover Fireplace, OK to Cover Elsewhere.
NEXT INSPECTION:	Reinspect.
RE-INSPECTION FE	E DUE?
IF RE	QUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION
Q	UESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:
	jeremy.haberman @co.kittitas.wa.us
	ECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 11 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506