



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00567

OWNER'S NAME: BERRY

DATE: 6/26/2015

TYPE: Footings

TIME STARTED: 12:54 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-18010-0026

	1. exterior pads/garage thickened footing ok

INSTRUCTIONS: ok to pour. 4 verts per sonotube when pouring. No rings called out.

NEXT INSPECTION: horizontal slab insulation/ plumbing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506