



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00567

OWNER'S NAME: BERRY

DATE: 7/8/2015

TYPE: Slab insulation

TIME STARTED: 12:42 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-18010-0026

| | |
|--|--|
| | 1. slab insulation ok. R-10 under entire slab w/ vapor barrier and wire mesh |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: ok to pour

NEXT INSPECTION: shearwalls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506