

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

PERMIT NUMBER:	BP-14-00567	OWNER'S NAME:	BERRY
DATE:	11/23/2015	TYPE:	Exterior shear
TIME STARTED:	10:34 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-18010-0026		

1. 3 missing hold downs at main floor. Bubbled on plan. See by framing		
2. Exterior shear ok		

**INSTRUCTIONS:** Ok to cover exterior

NEXT INSPECTION: plumb/mech

RE-INSPECTION FEE DUE?

V NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506