



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00567

OWNER'S NAME: BERRY

DATE: 5/16/2016

TYPE: Framing

TIME STARTED: 1:55 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-18010-0026

1. Correction 1 - Verify Hydronics @ Insulation
2. Correction 10 - Verify post caps @ Main Floor (Pantry & Stairs) at Insulation
3. Correction 17 - Verify straps @ beams above Mezz at Insulation
4. Other corrections complete
5. Ok to insulate

INSTRUCTIONS: Complete remaining corrections/Ok to insulate/Verify corrections @ insulation

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506