INSPECTION REPORT

PERIVITI NUIVIBER:	BP-14-00307	OWNER'S NAME:	BERRI		
DATE:	9/30/2016	TYPE:	Final		
TIME STARTED:	1:58 PM	INSPECTOR:	Justin Bennett		
MAP NUMBER:	20-15-18010-0026				
 Septic not approved WUIC not complete Provide weathertight membrane @ exterior (multiple locations) Provide temp landing @ rear slider Maintain fire separation @ garage Garage man door not self closing Fireplace not functional Provide self closing door to basement Provide railing to basement and garage Windows not tempered per plans Range Ok Plumbing Ok Blower door Ok Insulation Ok Energy Credits Ok Smoke/CO Ok INSTRUCTIONS: Complete above corrections/Complete WUIC/Finalize Septic/Re-Inspection					
NEXT INSPECTION: Re-Inspection					
RE-INSPECTION FEE		DAID DDIO2 TO 66115	\$		
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
	QUESTIONS? PLEASE CONTACT THE I ADDRESS:	NSPECTOR AT THE FO <u>iustin.bennett</u> @			
	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	idomi.berniett &			

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506

INSPECTION REQUEST LINE: 509-962-7694

INSPECTION REPORT

PERIVITI NUIVIBER:	BP-14-00507	OWNER'S NAME:	BERRI		
DATE:	9/30/2016	TYPE:	Final		
TIME STARTED:	1:58 PM	INSPECTOR:	Justin Bennett		
MAP NUMBER:	20-15-18010-0026				
Page 2					
INSTRUCTIONS: C	omplete above corrections/Comp	lete WUIC/Finalize	e Septic/Re-Inspection		
NEXT INSPECTION:	Re-Inspection				
RE-INSPECTION FEE	DUE? NO YES		\$		
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
INSPECTION REQUEST LINE: 509-962-7694					
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx					

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506