



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00577 OWNER'S NAME: SUNRIDGE II LLC
DATE: 10/3/2014 TYPE: Slab plumbing
TIME STARTED: 3:28 PM INSPECTOR: Amber Green
MAP NUMBER: 16-19-12000-0010

	1. DWV (5#/15min) - OK
	2. Slab Insulation OK

INSTRUCTIONS: OK to Cover

NEXT INSPECTION: Exterior Shear

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506