



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00665

OWNER'S NAME: BAUGHER

DATE: 1/16/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 3:16 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-30059-0004

	1. DWV at 6#-ok
	2. H2O at 65#-ok
	3. gas at 27#-ok
	4. insulaton and vapor barrier on exterior wall behind shower
	5. Insulate range vent.
	6. Complete post to beam hardware at porches and carport.

INSTRUCTIONS: ok to insulate

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506