



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00665 OWNER'S NAME: BAUGHER  
DATE: 3/20/2015 TYPE: Final  
TIME STARTED: 11:10 AM INSPECTOR: Justin Bennett  
MAP NUMBER: 18-19-30059-0004

	1. Grade gravel from rear foundation vent
	2. Caulk mechanical and gas penetrations at exterior of garage
	3. Range vent not installed
	4. Attach bases on porch beams
	5. Blower Door Test Not Complete. Pending.
	6. Sewer Not Approved. Pending.
	7. Complete fire caulking in garage
	8. Maintain fire separation in open air garage
	9. Install metal ducting from open air garage through fire separation wall
	10. Provide fire rated enclosure over speakers in attic
	11. Self closing door at fire separation must be functional
	12. Access is approved (AC-14-00127)

### INSTRUCTIONS:

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506