



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00665 OWNER'S NAME: BAUGHER
DATE: 3/27/2015 TYPE: Re-inspection
TIME STARTED: 12:54 PM INSPECTOR: Justin Bennett
MAP NUMBER: 18-19-30059-0004

	1. Blower door to be emailed
	2. Photo of garage speaker enclosure to be provided
	3. Complete fire caulking at penetrations in open air garage
	4. Corrections 1, 5, 6, 8, 10 & 11 Not Complete
	5. Provide final inspection on above ground LP tank prior to Final Re-inspection
	6. Corrections 2, 3, 4, 7, 9 & 12 Complete

INSTRUCTIONS: Final not complete/Do not occupy residence/Certificate of Occupancy has not been issued

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506