



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00668 OWNER'S NAME: ADDINGTON
DATE: 5/26/2015 TYPE: Framing
TIME STARTED: 12:39 PM INSPECTOR: Jeremy Haberman
MAP NUMBER: 19-16-06010-0015

	1. Framing OK.
	2. Gas Line Not On Test. Currently @ 5PSI.
	3. Verify Mechanical is Covered on this Permit#??
	4. Owner intends to store propane cannisters in built in cabinetry.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506