INSPECTION REPORT

PERMIT NUMBER: BP-14-00668 OWNER'S NAME: ADDINGTON

DATE:	5/28/2015	TYPE:	Gas piping
TIME STARTED:	10:52 AM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-16-06010-0015		
1. Gas @ 20#/15 mins - Ok			
INSTRUCTIONS:			
NEXT INSPECTION: Final			
RE-INSPECTION FEE D	OUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iustin_bennett @co.kittitas.wa.us			
 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆ 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506 			
411 N. Nuby Street, Suite 2, Eliensburg, WA 38320 Wildin Office Line: 503-302-7506			