



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00679

OWNER'S NAME: KOCH

DATE: 6/23/2016

TYPE: Plumbing

TIME STARTED: 1:20 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-31010-0031

1. DWV at 6#-ok
2. H2O at 52#-ok
3. Hydronics will need to be tested at 100#

INSTRUCTIONS:

NEXT INSPECTION: Frame/mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506