



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00697 OWNER'S NAME: COX
DATE: 12/10/2014 TYPE: Final
TIME STARTED: 3:01 PM INSPECTOR: Lou Whitford
MAP NUMBER: 17-19-06071-0002

	1. NOTE: THE REROOF AROUND THE EXISTING CHIMNEY DOES NOT HAVE STANDARD FLASHING
	2. EXISTING FLASHING - EXISTING CONDITION STONE CHIMNEY
	3. OK RE-ROOF WITH NOTE ABOUT CHIMNEY
	4. OK FINAL REROOF

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

lou.whitford@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506