



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00709

OWNER'S NAME: CASCADE VIEW INC

DATE: 11/17/2014

TYPE: Footings

TIME STARTED: 2:03 PM

INSPECTOR: Lou Whitford

MAP NUMBER: 18-18-27071-0144

	1. ROCK BOULDERS ARE NOT ALLOWED IN FTG TO SUPPORT REBAR.
	2. USE CONCRETE REBAR "CRADLES" FOR REPAR SUPPORT
	3. OK TO POUR WHEN REMOVED
	4. OK SLAB INSULATION

INSTRUCTIONS:

NEXT INSPECTION: SHEARWALLS

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ lou.whitford @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506