



KITTTAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-14-00709

OWNER'S NAME: CASCADE VIEW INC

DATE: 3/19/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 12:45 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-18-27071-0144

1. H2O at 100#-ok
2. DWV on stack-ok
3. vapor barrier needed behind showers over insulation
4. stamped truss sheete not on site.
5. tempered glass in bath window upstairs
6. add bearing studs under parallam in entry
7. fresh air to all habitable rooms required per plan review note in worksheet

**INSTRUCTIONS:** make corrections. Have stamped truss sheets on site. ok to insulate walls

**NEXT INSPECTION:** corrections/insulation

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto@co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506