## **INSPECTION REPORT**

BP-14-00709

**PERMIT NUMBER:** 

OWNER'S NAME: CASCADE VIEW

DATE:		7/9/2015	TYPE:	Final
TIME STARTED:		12:51 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:		18-18-27071-0144	ļ	
	1. Garage Fire Door Requires Self Closing Hinges.			
	2. Sewer and Access Not Signed on Permit Card.			
Install Hinges. Contact Public Works for Access Signature and City Utility for Sewer Sign Off. Inspector Will Accept Reciept for Sewer Hook Up as Evidence Of Completed Sewer Connection.				
NEXT INSPECTION: Re Inspect				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
jeremy.haberman @co.kittitas.wa.us				
<ul> <li>INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>				
			<u> </u>	