



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00731 OWNER'S NAME: LANDEN
DATE: 11/6/2015 TYPE: Insulation
TIME STARTED: 11:04 AM INSPECTOR: Jessica Contratto
MAP NUMBER: 21-13-17050-0001

	1. Corrections ok
	2. Insulation ok
	3. Foam gap at front entry door above left window
	4. Fireplace not installed yet. Will it be gas? Gas line will need inspection as will fire place clearances before cover

INSTRUCTIONS: ok to cover

NEXT INSPECTION: final or fireplace/gas line

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506