INSPECTION REPORT

TYPE:

INSPECTOR:

OWNER'S NAME: BV RESORT HOMES

Exterior shear

Jessica Contratto

BP-14-00735

4/29/2015

11:09 AM

PERMIT NUMBER:

TIME STARTED:

DATE:

| MAP NUMBER: | 20-15-29050-0074 |
|---|--|
| 1. tighter | n up nailing where indicated |
| 2. add 2 straps at back window bumpout | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| INSTRUCTIONS: complete above, ok to cover exterior | |
| | |
| NEXT INSPECTION: plumb/mech | |
| RE-INSPECTION FEE | DUE? |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION | |
| QU | ESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: |
| | jessica.contratto @co.kittitas.wa.us |
| INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506 | |
| | |