



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00735

OWNER'S NAME: EQUITY TRUST COMP

DATE: 7/1/2015

TYPE: Gas piping

TIME STARTED: 12:33 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29050-0074

	1. gas line cannot penetrate foundation wall to exterior below grade

INSTRUCTIONS: penetrate above grade before elbowing down to burial. Address and re-inspect

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506