



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00735

OWNER'S NAME: GINN

DATE: 3/30/2016

TYPE: Final

TIME STARTED: 3:16 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29050-0074

1. Outside Gas Line Not at Required PSI.
2. Hot Tub Installation Not Permitted.
3. Sewer Connection Not Verified.
4. Energy Credits Not Verifiable. 5b Attempted.
5. Hand Rail Not Per Code.
6. All Prior Corrections OK.
7. Plumbing Final OK.
8. Fireplace Final OK.
9. Stair At Garage Not Acceptable.

INSTRUCTIONS: MAke Corrections Above.

NEXT INSPECTION: Final

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506