INSPECTION REPORT

PERMIT NUMBE	r: BP-14-00736	OWNER'S NAME:	COLLINS/JACKSON	
DATE:	11/24/2015	TYPE:	Final	
TIME STARTED:	12:10 PM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:	20-15-19050-0067			
1. Grade 8" Above Siding At Front Entry.				
2. 220v Electrical Not Terminated at Exterior (2) Places.				
3. Plumbing Final OK.				
4. Missing Siding and Window Trim on Exterior.				
5. HVAV Air Returns and Some Supply Ducts Not Trimmed.				
6. Garag	6. Garage Door Not Self Closing.			
7. Fire MArshall Final Not Complete. Sprinkler Heads Not Trimmed.				
INSTRUCTIONS: Make Corrections.				
Make Corrections.				
NEXT INSPECTION: Final.				
RE-INSPECTION FEE DUE? VES \$				
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION				
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:				
ieremv.haberman @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506				