



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00748

OWNER'S NAME: BROOKS

DATE: 11/20/2014

TYPE: Rough-in plumbing

TIME STARTED: 12:12 PM

INSPECTOR: Amber Green

MAP NUMBER: 18-19-18040-0006

	1. Address must be posted at Wilson Creek and at private drive prior to any further inspections.
	2. DWV (6#/15min) - OK H2O (60#/15min) - OK

INSTRUCTIONS:

NEXT INSPECTION: Framing/Mechanical

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ amber.green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506