



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00748 OWNER'S NAME: BROOKS
DATE: 12/12/2014 TYPE: Mechanical
TIME STARTED: 12:32 PM INSPECTOR: Amber Green
MAP NUMBER: 18-19-18040-0006

	1. Complete draftstops at fireplaces.
	2. A35 clips from sheathing to rafters per 9/A8 at covered porch.
	3. H2.5s from rafters to beams per plans at covered porch.
	4. Rafter to rafter straps at ridge per plans at covered porch.
	5. Range vent pipe to be smooth wall metal.
	6. Install shields at fireplace vent pipe to maintain clearances from insulation.

INSTRUCTIONS: Ok to Insulate. Will see above corrections at insulation inspection. Can see porch corrections at later date if needed.

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE? ☒ NO ☐ YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

amber.green @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506