INSPECTION REPORT

BP-14-00764 OWNER'S NAME: HALL

PERMIT NUMBER:

DATE:		4/7/2015	TYPE:	Insulation	
TIME STARTED:		10:23 AM	INSPECTOR:	Jeremy Haberman	
MAP NUMBER:		20-14-02051-160)1		
	1. Insuation OK.				
	2. Garage is Unheated. Vaults Insulated to an R-38, Walls to an R-21, Floor to an R-30.				
	3. Windows U-Factor 0.32.				
INSTRUCTIONS: OK to Cover					
NEXT INSPECTION: Final.					
RE-INSPECTION FEE DUE? NO YES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	jeremy.haberman @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •					
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506					