



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00785 OWNER'S NAME: BACK COUNTRY
 DATE: 7/8/2015 TYPE: Floor framing
 TIME STARTED: 9:57 AM INSPECTOR: Justin Bennett
 MAP NUMBER: 19-15-07060-0011

1. Provide crawl space access as shown on sheet 5
2. Provide HD's at bearing wall per detail 9/S1
3. Complete HD installation per detail 4/S1
4. Install A35's with SDS screws @ rim per detail 10/S1
5. Provide engineers approval for two posts not centered on sono tube footings
6. Install DTT2Z's as indicated on sheet 5
7. Provide blocking @ hold down to floor framing per detail 9/S1

INSTRUCTIONS: Make corrections above/Approved drawings must be on site/Permit card must be on site/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506