INSPECTION REPORT

PERMIT NUMBER:	BP-14-00797	OWNER'S NAME:	WILLIAMS
DATE:	5/15/2015	TYPE:	Framing
TIME STARTED:	10:03 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	17-17-11040-0019		
1. Shearv	valls OK.		
2. Framing OK.			
3. Install Galv. Nails in Exterior Sheating to Plate.			
INSTRUCTIONS: OK to Cover Exterior.			
NEXT INSPECTION:	Final		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
 ■ INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 			

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506