INSPECTION REPORT

TYPE:

INSPECTOR:

OWNER'S NAME:

UNIONVILLE RANCH

Jeremy Haberman

Mono pour

BP-14-00813

1/29/2015

10:10 AM

PERMIT NUMBER:

TIME STARTED:

DATE:

MAP N	UMBER: 19-17-06040-0009
	1. Thickened/Widened Footings not complete. Pony wall footing not complete.
INSTRUCTIONS: Complete 30x30x10 footings. Dowel into existing per detail. Email photos to email address below.	
NEXT I	NSPECTION: Framing.
RE-INS	PECTION FEE DUE? VES \$
	IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION
	QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:
	@co.kittitas.wa.us
	 INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506
1	· · · · · · · · · · · · · · · · · · ·