



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00826 OWNER'S NAME: ERDMAN
DATE: 3/17/2015 TYPE: Foundation walls
TIME STARTED: 10:32 AM INSPECTOR: Justin Bennett
MAP NUMBER: 18-18-31051-0004

	1. Foundation wall does not have #4 @ 6"oc
	2. Spread footing @ NE corner not installed per drawings
	3. Interior pier at North spread not installed per drawings

INSTRUCTIONS: Do not pour walls/Complete above or provide engineer letter of acceptance for installation.

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506