



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00826

OWNER'S NAME: ERDMAN

DATE: 5/18/2015

TYPE: Rough-in plumbing

TIME STARTED: 9:15 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 18-18-31051-0004

	1. Supply @ 20# - Needs to be @ 50#/15 mins
	2. Waste stack not full on second floor - refill waste system

INSTRUCTIONS: Complete corrections above/Re-inspection

NEXT INSPECTION: Plumbing Re-inspection

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506