## **INSPECTION REPORT**

PERMIT NUM	BER:	BP-14-00826		OWNER'S NAME:	ERDMAN	
DATE:		6/19/2015		TYPE:	Insulation	
TIME STARTE	D:	9:04 AM		INSPECTOR:	Justin Bennett	
MAP NUMBE	R:	18-18-31051-000	)4			
1. Med	1. Mechanical Ok					
2. Attic Access Ok						
3. Wall Insulation Ok						
4. Corrections not complete						
5. Plu	5. Plumbing not installed @ WH location shown on drawings					
INSTRUCTIONS: Complete exterior deck corrections/Ok to cover once water heater plumbing is						
	ins	talled				
NEXT INSPECT	rion: <sub>F</sub>	inal				
RE-INSPECTIO	N FEE C	DUE? NO	YES		\$	
	IF REQL	IIRED, RE-INSPECTION FI	EES MUST BE	PAID PRIOR TO SCHE	DULING A RE-INSPECTION	
	QUE	STIONS? PLEASE CONTA				
iustin.bennett @co.kittitas.wa.us						
<ul> <li>INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926</li> <li>Main Office Line: 509-962-7506</li> </ul>						