INSPECTION REPORT

TYPE:

PERMIT NUMBER:

DATE:

BP-14-00830

3/23/2015

OWNER'S NAME: SEUBERT

Exterior shear

TIME STARTED:	11:03 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	17-20-04051-0004		
1. exteri	or shear ok		
2. add h	old downs to ABWP in gi	eat room per	plan
INSTRUCTIONS: S	see hold downs at next inspection	n. ok to cover exte	rior
NEXT INSPECTION:	frame/plumb/mech		
RE-INSPECTION FE	E DUE? NO YES	6	\$
IF RE	QUIRED, RE-INSPECTION FEES MUST B	E PAID PRIOR TO SCH	HEDULING A RE-INSPECTION
Q	UESTIONS? PLEASE CONTACT THE INSP	ECTOR AT THE FOLLO	OWING E-MAIL ADDRESS:
	jess	sica.contratto @co	.kittitas.wa.us
	CTION REQUEST LINE: www.co.kitt 11 N. Ruby Street, Suite 2, Ellensburg, V		