



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-14-00830

OWNER'S NAME: SEUBERT

DATE: 4/10/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 1:57 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-20-04051-0004

	1. Waste on stack - Ok
	2. Supply @ 125#/15 mins - Ok
	3. Trusses Ok
	4. Mechanical Ok
	5. Framing Ok
	6. Ok to insulate

INSTRUCTIONS: Verify vapor barrier at showers/tubs at insulation/Ok to insulate

NEXT INSPECTION: Insulation

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506