



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00830

OWNER'S NAME: SEUBERT

DATE: 6/19/2015

TYPE: Re-inspection

TIME STARTED: 12:19 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-20-04051-0004

	1. fire caulk gap between sheetrock at ceiling to top plate in garage
	2. garage door to residence not self closing/latching
	3. have permit card/plans on site in visible location
	4. sewer/access approval??
	5. contact number not left on inspection request

INSTRUCTIONS: complete above

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506