



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-14-00839

OWNER'S NAME: WAILES

DATE: 2/18/2016

TYPE: Plumbing

TIME STARTED: 10:41 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-35054-0017

1. DWV on stack - Ok
2. Water @ 50#/15 mins - Ok
3. Mechanical Ok

INSTRUCTIONS: Complete L&I inspection prior to framing

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506