



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00040

OWNER'S NAME: EMMERTON

DATE: 5/22/2015

TYPE: Rough-in plumbing

TIME STARTED: 10:13 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-24052-1203

	1. Corrections not complete
	2. Waste not on test
	3. Supply @ 90#/15 mins - Ok
	4. Plumbing rough-in Ok

INSTRUCTIONS: Complete Shear corrections/Waste on Test/Re-inspection

NEXT INSPECTION: Re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506