INSPECTION REPORT

TYPE:

INSPECTOR:

OWNER'S NAME: EMMERTON

Re-inspection

Justin Bennett

PERMIT NUMBER: BP-15-00040

DATE:

TIME STARTED:

6/10/2015

9:50 AM

MAP NUMBER: 19-16-24052-1203
1. Corrections Ok
2. Mechanical Ok
3. Trusses Ok
4. Provide strap @ garage beam per detail 2/S5
5. Provide engineers letter for door in rear of garage not shown on drawings
INSTRUCTIONS: Make corrections above/Verify @ insulation/Ok to insulate
NEXT INSPECTION: Insulation
RE-INSPECTION FEE DUE? VES \$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:
iustin_bennett @co.kittitas.wa.us
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506