INSPECTION REPORT

TYPE:

BP-15-00042

2/9/2015

PERMIT NUMBER:

DATE:

OWNER'S NAME:

MCKEAN

Stove or fireplace

| TIME STARTED: | 2:52 PM | INSPECTOR: | Jeremy Haberman |
|---|--|--------------------|---------------------------|
| MAP NUMBER: | 17-19-06062-0011 | | |
| | | | |
| | Line OK. 26#/15 min. | | |
| 2. Firep | lace Must be Raised per | Installation N | lanual or Install Hearth. |
| 3. Homeowner Stated Carpet Will be the Finished Floor Covering. | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| INSTRUCTIONS: (| Complete Corrections. | | |
| | | | |
| NEXT INSPECTION | : Reinspect. | | |
| RE-INSPECTION FE | E DUE? NO YE | S | \$ |
| IF RE | QUIRED, RE-INSPECTION FEES MUST B | E PAID PRIOR TO SO | CHEDULING A RE-INSPECTION |
| Q | UESTIONS? PLEASE CONTACT THE INSP | ECTOR AT THE FOLI | LOWING E-MAIL ADDRESS: |
| | jeren | ny.haberman @c | o.kittitas.wa.us |
| | ECTION REQUEST LINE: www.co.kit 11 N. Ruby Street, Suite 2, Ellensburg, | | |
| | | | |