## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00055	OWNER'S NAME:	WARREN
DATE:	4/24/2015	TYPE:	Footings
TIME STARTED:	11:31 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	17-19-35052-0004		
1. Setbac	cks OK.		
2. Mono	OK.		
3. Complete Strap Installation Prior to Pour.			
4. Verify Complete Set of Drawings are Onsite. Laminated Pages Found Detached and Loose in			
Footing Trenches.			
5. Verify Strapping at Floor Framing.			
INSTRUCTIONS:			
NEXT INSPECTION:	Floor Framing		
RE-INSPECTION FEE I	DUE? NO YES		\$
IF REQ	UIRED, RE-INSPECTION FEES MUST BE	PAID PRIOR TO SCHE	DULING A RE-INSPECTION
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
<ul> <li>INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ◆</li> <li>411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ◆ Main Office Line: 509-962-7506</li> </ul>			