



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00055

OWNER'S NAME: WARREN

DATE: 7/22/2015

TYPE: Re-inspection

TIME STARTED: 2:38 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-19-35052-0004

	1. Wall Insulation OK.
	2. Floor Insulation OK.
	3. Fenestration U Factor Not Verified as Stickers were Removed. Provide Verification from Manufacturer.
	4. Vapor Barrier Not Installed. Use of PVA Primer Required.

INSTRUCTIONS: OK to Cover

NEXT INSPECTION: Final.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506