



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00056

OWNER'S NAME: LARSON

DATE: 2/22/2017

TYPE: Final

TIME STARTED: 12:59 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-14050-0924

1. Fireplace not functional
2. Complete fire separation in Mech Rm
3. Caulk exterior @ gas meter
4. Blower Door Ok
5. FLS Ok
6. Plumbing Ok
7. Trellis Framing Ok
8. Insulation Ok
9. Access Ok
10. Water/Sewer letter Ok

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506