



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00081 OWNER'S NAME: NELSON SIDING LLC
DATE: 4/1/2015 TYPE: Slab insulation
TIME STARTED: 2:13 PM INSPECTOR: Justin Bennett
MAP NUMBER: 19-14-03000-0085

	1. Underslab plumbing on Stack - Ok
	2. Underslab insulation - Ok
	3. Thickened footings - Ok
	4. Ok to pour slab

INSTRUCTIONS: Ok to pour

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506