## **INSPECTION REPORT**

PERMIT NUMBER:	BP-15-00081	OWNER'S NAME:	NELSON SIDING LLC
DATE:	6/10/2015	TYPE:	Final
TIME STARTED:	12:20 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	19-14-03000-0085		
1. Plumbing Ok			
2. Mechanical Ok			
3. Fireplace Ok			
4. Complete fire seperation in garage			
5. Blower door @ 6.5 - Needs to be a maximum of 5.0			
6. Septic final not complete			
7. Verify Access Permit			
INSTRUCTIONS: Complete corrections above/Re-inspection			
NEXT INSPECTION: Re-inspection			
RE-INSPECTION FEE DUE? VES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iustin_bennett @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: <a href="www.co.kittitas.wa.us/cds/request.asp">www.co.kittitas.wa.us/cds/request.asp</a> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			