INSPECTION REPORT

PERMIT NUMBER:		BP-15-00093	OWNER'S NAME:	EVERGREEN VALLEY LLC	
DATE:		4/6/2015	TYPE:	Frame-Plumb-Mech	
TIME STARTED:		12:36 PM	INSPECTOR:	Justin Bennett	
MAP NUMBER:		20-14-12057-0002			
	1. Waste	not on test			
	2. Supply @ 28# - Needs to be 50# or greater				
	3. Trusses Ok				
	4. No drawings on site - Recall framing inspection				
	5. Provide Truss kicker bracing at front gable end				
INSTRUCTIONS: Make truss correction above/No drawings on site/Recall Framing inspection					
NEXT INSPECTION: Re-inspection					
RE-INSPECTION FEE DUE? VES \$					
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION					
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:					
	justin.bennett @co.kittitas.wa.us				
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506					