INSPECTION REPORT

TYPE:

BP-15-00110

4/20/2015

PERMIT NUMBER:

DATE:

OWNER'S NAME: CASCADE VIEW INC

Slab

TIME STARTED:	10:01 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	18-18-27071-0138		
1. comp	lete thickened footings po	er plan. Curre	ent ones ok
	lee thermal break at hous	<u> </u>	
INSTRUCTIONS: 0	complete above. ok to pour		
NEXT INSPECTION:	shearwalls		
RE-INSPECTION FEI	E DUE? NO YE	5	\$
IF RE	QUIRED, RE-INSPECTION FEES MUST B	E PAID PRIOR TO SCI	HEDULING A RE-INSPECTION
Q	UESTIONS? PLEASE CONTACT THE INSP	ECTOR AT THE FOLL	OWING E-MAIL ADDRESS:
	jess	sica.contratto @co	o.kittitas.wa.us
	CTION REQUEST LINE: www.co.kitt 11 N. Ruby Street, Suite 2, Ellensburg,		