



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00121

OWNER'S NAME: KITTITAS COUNTY HA

DATE: 1/22/2016

TYPE: Mechanical and plumbir

TIME STARTED: 10:35 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-16-24051-0913

	1. Exhaust fans ok
	2. DWV not on test
	3. Trusses ok
	4. Framing ok
	5. Complete shear transfer at trusses over deck entry wall per detail5/D1 per note on roof framing page in first section of plans
	6. Complete fire marshal inspections on sprinkler system
	7. H2O at 55#-ok

INSTRUCTIONS: Call for re-inspect on plumbing. Clarify location of supply gauge. Clarify if mini split will be omitted and what option will be chosen for energy credit. Ok to insulate exterior walls

NEXT INSPECTION: Plumbing/insulation/truss shear detail

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506